

Replaced	Date	Serviced Date	
Water Softener Units - 3 black tanks	February 2018	08/2018	
		03/2019	
		08/2019	
Sump Pumps - Both Replaced			
Sump Pump in crawl space	November 2018		
Sump Pump in Laundry Room	05/2019		
Sump Pump in Laundry Room Replaced	10/2021		
			Purchased a used 2013 Hobart Unit, was serviced until 2017. Installed by Eco-Lab and then assist installed by person (John) whom we purchased from
Sanitizer / Dishwasher in Kitchen	06/2019	09/2019	Fixed Washer around motor to keep it from not leaking.
		02/2020	Repaired and replaced motor on sanitizer. Was leaking all over floor
Replaced septic pipe from tank into leach field	07/2020		
Repaired Leak in Room 5 from Room 7	05/2019		
	02/2021		
Repaired leak in public bathroom from suite 1	04/2020		
Frozen Pipe in R #6, fixed piped and spray foamed	02/2021		
Water Pipes under Inn Guest Rooms Replaced	11/2021		flow.