



## Laboratory Report

Steven Chase  
174 Beals Hill Road  
Waterville, VT 05492

100725

PROJECT: 174 Beals Hill Road

WORK ORDER: 1712-30176

DATE RECEIVED: December 20, 2017

DATE REPORTED: December 21, 2017

SAMPLER: Steven

VTP

- 001

Site: Supply Well

Date Sampled: 12/20/17 Time: 7:28

Property Address (911): 174 Beals Hill Road

Waterville

VT

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	Qualifiers
Total Coliform	< 1.0	MPN/100mls	SM20 9223B(97)	12/20/17 11:43	W AKJ	
e. coli	< 1.0	MPN/100mls	SM20 9223B(04)	12/20/17 11:43	W AKJ	

The Federal SDWA considers this water bacteriologically **Acceptable** for consumption.

EPA Coliform Acceptance Criteria MCL

Total Coliform &lt; 1.0 MPN/100ml or Absent

e. coli &lt; 1.0 MPN/100ml or Absent

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory

Reviewed by:

Harry B. Locker, Ph.D.  
Laboratory Director

[www.endynelabs.com](http://www.endynelabs.com)

160 James Brown Dr., Williston, VT 05495  
Ph 802-879-4333 Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766  
Ph 603-678-4891 Fax 603-678-4893

