



P.O. Box 69, 174 Thomas Lane, Stowe, VT 05672 (802) 253-4190 • (802) 253-4553 Fax

Email: office@gouldcorpvt.com

www.gouldcorpvt.com

Date: April 30, 2018

Ann Turkle
6B Randall Street
Waterbury, VT 05676

RE: House Inspection 320 Lower Main Street Johnson VT

Tel: 802-730-2312
Email: acturkle@gmail.com

This is an Estimate for Electrical Work ...

Main House:

- 1) Trace and label (2) sub panels on 2nd floor.
- 2) Cover and terminate or remove wires underneath panel on 2nd floor.
- 3) Install GFI receptacles, (5) located in 1st floor apartment kitchen & (1) located in basement for sump pump.

Basement:

- 1) Change out porcelain lamp holder with receptacle to just a lamp holder and terminate 12/2 wire to the right of the panel.

Porches:

- 1) Remove wall sconces on front porch and blank off.
- 2) Change receptacle on back porch to a weatherproof GFI.

Attic:

- 1) Terminate knob & tube wiring in attic properly.

Shed or Studio Apartment:

- 1) Change out (2) interior receptacles to GFI receptacles.
- 2) Add (1) exterior weatherproof GFI receptacle.