

ZONES

- 7 Entry Low temp
- 8 Apt Low temp
- 9 GARAGE Dr
- 10 Entry Hall motion Batteries replaced 9/04 Due to false alarms they were low
- 11 Apt motion
- 12 Apt Door
- 13 Apt Heat
- 14 Frt Door
- 15 Kit Door
- 16 Liv Rm motion
- 17 " " Heat
- 18 2nd Fl. motion
- 19 master bed Heat
- 20 1st Fl. Low temp Loop
- (21) Furnace Rm smoke
- 22 Apt smoke
- 23 2nd Fl. smoke
- 24 Lib smoke replaced 9/16/04 Due to False Alarms
- 25 Entry Hall smoke

49 \		55 \	
50 \	Q Key	56 \	Q Key
51 \		57 \	
52 \			
53 \	Q Key		
54 \			