



Brook Field Service

Providing Shelter from the Storm

Toll Free 24/7: 866-POWER97
Phone: 802-485-6567
Email: info@brookfieldservice.com
829 VT Route 12 South, Northfield, VT 05663

Inspection Report

Major Inspection

Minor Inspection

Date: 7-7-20

Customer: Chamandy, Glenn & Amel-Cooling Contact Name: _____ Phone #: (802) 635-2566

Location Address: 2684 Robinson Spring Road

Location Description: _____

Generator

Make Kohler
Model # 50rzgb
Serial # 2133043
Spec # Gm39374-g
KW 50

Engine

Make Gm
Model # 5.0L
Serial # 5p0l08927
Spec # Na
Cyl. 8

ATS

Make Na
Model # Na
Serial # Na
Spec # Na
Amps Na

Addtl. Info

Hours 356.6
Cooling Liquid
Fuel LP
Phase Single
Voltage 120/240
Fuel Level _____

Engine Inspection

Enclosure Inspection: ☒ Cleaned
Exhaust System ☒ Checked
Spark Plugs N/A ☒ Checked/Cleaned ☒ Replaced QTY: 8
Oil ☒ Checked Replaced QTY: _____
Oil Filter N/A ☒ Checked Replaced QTY: _____
Fuel Filter ☒ N/A ☒ Checked Replaced QTY: _____
Air Filter ☒ Checked/Cleaned Replaced QTY: _____
Battery Terminals ☒ Checked/Cleaned Replaced QTY: _____
Battery Condition Pass Fail Replaced QTY: _____
Battery Charge Rate: _____ Volts: _____ Type: Trickle/
Gaskets ☒ Checked Rec. Replacement
Governor ☒ Checked

Parts Used


Spark Plug #: Gm16531
Oil Type: _____
Oil Filter #: _____
Fuel Filter #: _____
Air Filter #: _____
Terminal #: _____
Battery #: Mt24

Cooling System Inspection

Coolant Level NA ☒ Normal Low - Added Coolant QTY: _____ Coolant
Nitrite NA ☒ Normal Req. Additive Recommend Flush
Freeze Point NA ☒ Normal Recommend Coolant Change
PH Test NA ☒ Normal Req. Additive

Electrical Inspection

Voltage ☒ Checked Load: _____ NL: 240
Frequency ☒ Checked Load: _____ NL: 60
Safety Shutdown N/A Checked
Transfer Switch Test Pass Fail
Exercise Day: N/A Time: N/A N/A N/A
Switch in Auto? ☒ Yes No

**Recommended Repairs:****Customer Requests****Misc. Parts**

QTY	Description	QTY	Description	QTY	Description
1	Gm47570	1	Gm16570		
1	Gm16420	1	Gm79585-s		
1	Gm22939	5ft	5/8 heater hose		
1	Gm14098	5gal	Coolgaurd		
1	Gm16132				
1	352327				

F# _____

VT TQP# _____

Notes

On site to preform coolant system service and ignition system service. Disabled generator and de energized block heater. Drained coolant from system. Removed guards and fan belt. Removed upper and low radiator hoses. Removed block heater hoses. Removed thermostat. Installed new parts for all that were removed with new gasket. Filled with new coolant and energized block heater. Let block heater run. Removed and installed new spark plugs, plug wires, cap and ignition rotor. Checked oil and ran unit no load for 45 minutes. Verified unit came up to temperature and no leaks are present. Unit looks and runs well at this time.

Tech Time In: 9: 00 AM

Tech Time Out: 1: 00 PM

Customer Signature: _____

Eric Parker _____